

SERTIFIKAT PRODUK

PRODUCT CERTIFICATE

No. 003/LSP/QI/012-X/2023

Tanggal terbit (*Date of issuance*)

6 Oktober 2023

Masa berakhir (*Date of expiry*)

5 Oktober 2027

LSPro Qualis Indonesia memberikan Sertifikat Produk Penggunaan Tanda SNI (SPPT-SNI) berdasarkan Sertifikasi Tipe 5, kepada:

LSPro Qualis Indonesia hereby granted the SPPT-SNI pursuant to Certification Type 5 to:

Oriental Copper Co., Ltd

Dengan Alamat Audit (*Audit Address*) : 700/45 Amata City Chonburi Industrial Estate, Klongtumru, Amphur Muang, Chonburi 20000, Thailand

Alamat Kantor (*Office Address*) : 27th Fl., Bangkok Insurance / Y. W. C. A Building
25 South Sathon Road, Thungmahamek, Sathon, Bangkok 10120, Thailand

Importir (*importer*) : PT. PENTAMITRA ABADI

Direktur (*Director*) : Indrawan Tanaya

Alamat importir (*Importer Address*) : Jl. Pangeran Jayakarta 141 Blok E No. 5, Kel. Mangga Dua Selatan, Kec. Sawah Besar, Jakarta Pusat – DKI Jakarta

Nama produk (*Product Name*) : Bus Bar Tembaga (*Copper bus bars*)

Merek dagang (*Brand*) : OC-ETP

No. Perjanjian (*MoU No.*) : 003/LSP-MoU/QI/12-X/2023

Mutu produk di atas telah memenuhi standar persyaratan yang ditetapkan dalam Standar Nasional Indonesia

The above mentioned product has fulfilled the requirements as stated in Indonesian National Standard

SNI 8760-2019

Bus Bar Tembaga (Copper bus bars)

Sertifikat ini hanya berlaku untuk jenis produk sesuai yang tercantum dalam lampiran sertifikat

This certificate is valid only for product types as stated in certificate appendices

Ditandatangani secara elektronik oleh

Digitally signed by



Ujiono
LSPro Manager



Pindai untuk verifikasi registrasi sertifikat di
Kementerian Perindustrian
Scan to verify certificate registration in
Ministry of Industry

LAMPIRAN 1

LABEL PENGELOMPOKAN PRODUK SERTIFIKAT No : 003/LSP/QI/12-X/2023

Oriental Copper Co., Ltd

700/45 Amata City Chonburi Industrial Estate, Klongtumru,
Amphur Muang, Chonburi 20000, Thailand

1	MERK	: OC-ETP			
	NAMA PRODUK	: SNI 8760-2019			
	STANDAR PRODUK	: Bus Bar Tembaga (Copper bus bars)			
No	Jenis Produk	Dimensi	Jenis	Temper	No. Laporan Hasil Uji
1	Bus Bar Tembaga (Copper bus bars)	Panjang : 1000 mm – 4000 mm Tebal : 2 mm – 76,2 mm Lebar : 15 mm – 305 mm	C1100	0	QI-23/09/0087
				0	QI-23/09/0088
				¼ H	QI-23/09/0089
				½ H	QI-23/09/0090
				1 H	QI-23/09/0091
			C1020	0	QI-23/09/0092
				0	QI-23/09/0093
				¼ H	QI-23/09/0094
				½ H	QI-23/09/0095
				1 H	QI-23/09/0096

Qualis
LSPro